



Certificate of conformity

001/006558

AENOR certifies that the organization

FIRAT PLASTIK, KAUÇUK VE SAN. TIC. A.S.

registered office TURKOBA KOYU, P.K. , 12 34907 BUYUKCEKMECE (Istanbul - Turquía)

supplies **Polypropylene pipes (PP-R) / polypropylene glass fiber (PP-R FV) / polypropylene (PP-R) for installation of hot and cold water inside the building structure**

in compliance with ESPECIFICACIÓN TÉCNICA AL RP 01.72

DESCRIPTION Marca comercial / Trademark: FIRAT
Contenido en fibra de vidrio total / Fiberglass content: 8%
Contenido en fibra de vidrio de la capa intermedia / Fiberglass content of the middle layer: 18%

See annex for more information.

Production site TURKOBA KOYU, P.K. , 12 34907 BUYUKCEKMECE (Istanbul - Turquía)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 01.72.

First issued on 2016-02-10

Last issued on 2026-02-10

Validity 2031-02-10

Rafael GARCÍA MEIRO
CEO



Certificate of conformity

001/006558

Annex to Certificate

DESCRIPTION Marca comercial / Trademark: FIRAT
Contenido en fibra de vidrio total / Fiberglass content: 8%
Contenido en fibra de vidrio de la capa intermedia / Fiberglass content
of the middle layer: 18%

SERIE	DIAMETERS (mm)	APPLICATION CLASS / DESIGN PRESSURE (bar)	OPACITY
2,5	20 - 25 - 32 - 40 - 50 - 63 - 75 - 90 - 110	1/10 ; 2/8 ; 4/10 ; 5/6	No
3,2	20 - 25 - 32 - 40 - 50 - 63 - 75 - 90 - 110	1/8 ; 2/6 ; 4/10 ; 5/6	No

First issued on 2016-02-10
Last issued on 2026-02-10
Validity 2031-02-10

